



# Cleanroom<sup>®</sup> Suitable Materials

**FAKOLITH Farben GmbH**  
Report No. FA 2604-1759  
Cleanroom (atmospheric)

**DISPERLITH ELASTIC**  
Biological Resistance:  
excellent

## FLOORING & COATING

### Single product Biological Resistance

### Qualification Certificate

We hereby certify that the material stated above, provided by

**FAKOLITH Farben GmbH**  
Fürth (Odenwald), Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number FA 2604-1759.

The biological resistance of DISPERLITH ELASTIC (color: white) regarding to growth intensity was investigated in accordance with ISO 846 and classified with the following result:

| Biological resistance                   | Growth intensity | Classification |
|---|------------------|----------------|
| Procedure A<br>(resistance to fungi)    | 0                | excellent      |
| Procedure C<br>(resistance to bacteria) | 0                | excellent      |
| <b>Overall result</b>                   | <b>excellent</b> |                |

The classification is based on a worst-case consideration of the Procedures A and C.

This document only applies to the named product in its original state and is valid for a period of 5 years from the current date the document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

The norms stated generally refer to the version valid at the time of the tests.

FA 1803-1018  
Report No. first document

Stuttgart, April 13, 2018  
Place, date of first document issued

FA 2604-1759  
Report No. current document

Stuttgart, April 30, 2026  
Place, current date

on behalf of   
Dr.-Ing. Frank Bürger, head of business unit Testing and Certification